



Mark the location of the maintenance shaft
(tick appropriate box)

h = _____ mm (installation height, max. 2000 mm)

1	Cesspool MK-9	Ø1600×4700 mm		1
	Glass-reinforce plastic (GRP) "Vesmaco Composite", pH 3-10, heat resistance max 40°C			
	Total volume		9000 l	
2	Inlet pipe	PVC	D110	1
3	Maintenance shaft (tick appropriate box)			
	Shaft Ø200, h= 500...1000 mm <input type="checkbox"/>			
	OPTION: Shaft Ø400, h= 500...1500 mm <input type="checkbox"/>			
	OPTION: Shaft Ø600, h= 1000...2000 mm <input type="checkbox"/>			
4	Cover (tick if appropriate)			
	Plastic cover <input type="checkbox"/>			
	OPTION: Cover (EN 124) — A15 <input type="checkbox"/> / B125 <input type="checkbox"/> / C250 <input type="checkbox"/> / D400 <input type="checkbox"/>			
5	Ventilation pipe connection	PVC	D110	1
6	OPTION: Ventilation pipe <input type="checkbox"/> (tick if appropriate)	PVC	D110	(1)
7	OPTION: Anti-odour air filter <input type="checkbox"/> (tick if appropriate)			
				(1)
8	OPTION: High level alarm device <input type="checkbox"/> (tick if appropriate)			
				(1)
9	Anchor strap with tensioner			
				5

Title, Supplementary title
Cesspooli MK-9 A3 1 : 35

Vesmaco

Vesmaco OÜ
Katusepapi 6, 11412 Tallinn, Estonia
www.vesmaco.ee

MK-9-D1600-L4700_EN

Document type General assembly drawing	Document status Customer drawing
Article number 910016090	Date of issue 09.07.2020
	EN 1/1

Approved by the client:
 _____ 20_____
 (date) (client's representative)

For installation instructions, check "Installation Manual for Underground Horizontal Tanks of Glass-Reinforced Plastics (GRP)" or special instructions provided with the product.
 Positions of anchoring and anchore straps are shown as example and might vary from those required in your case.
 Vesmaco OÜ reserves the right to make unilaterally changes.